

March 15, 2012

Electric Power Development Co., Ltd.

Suspension of No. 1 Unit at Isogo Thermal Power Plant

Electric Power Development Co., Ltd. (hereinafter, “J-POWER”) hereby announces that operation of the No. 1 unit of the Isogo Thermal Power Plant (location: Isogo-ku, Yokohama, Kanagawa Prefecture, rated unit output: 600MW) was suspended this morning at 6:00 o'clock after output of the unit was reduced following confirmation of a steam leak from the steam boiler attemperator during rated output operation.

J-POWER is currently investigating the cause of the leak and intends to proceed with repairs and any other necessary measures once results of the investigation are known. At this time there are no immediate plans to resume operation of the unit.

Reference: Overview of the Isogo Thermal Power Plant

Location	Isogo-ku, Yokohama, Kanagawa Prefecture
Fuel	Coal
Output	1,200MW (No. 1 Unit: 600MW; No. 2 Unit: 600MW)
Start of Operations	April 2002: Start of operations of new No. 1 Unit July 2009: Start of operations of new No. 2 Unit

Attachment: Steam Boiler Attemperator Diagram Illustrating Area of Steam Leak

【Diagram Illustrating Area of Steam Leak at Steam Boiler Attenuator】

