

September 5, 2014

Electric Power Development Co., Ltd.

Suspension of Hydroelectric Power Generation at Tedorigawa No. 1 Power Station

Electric Power Development Co., Ltd. (hereinafter, “J-POWER”) confirmed that the wire suspending the weight that opens and closes the water intake gate at the bottom of the Tedorigawa Dam is broken during an inspection of the Tedorigawa No. 1 Power Station (location: Hakusan City, Ishikawa Prefecture, output: 250 MW) on September 3. Because the effect on power generation resulting from the dropping of the weight is a concern, the company suspended power generation at 3:16 PM on September 3.

An inspection is currently being conducted, and necessary steps such as repairs are being taken based on the results of the inspection.

Expected resumption of operation is not known at this time.

[Attachment] Cross-section diagram of the Tedorigawa Dam intake tower

Reference: Overview of the Tedorigawa No. 1 Power Station

Location	Higashifutakuchi, Hakusan City, Ishikawa Prefecture
Power generation format	Dam conduit type
Output	250 MW (No. 1 Unit: 125 MW, No. 2 Unit: 125 MW)
Start of operations	August 1979

Cross-section diagram of the Tedorigawa Dam intake tower

